# **SIEMENS**

## Data sheet

## 3RT1026-1AP64



CONTACTOR, AC-3 11 KW / 400 V, AC 220 V 50 HZ / 240 V 60 HZ, 3-POLE, 2 NO + 2 NC, SIZE S0, SCREW CONNECTION

Figure similar	
product brand name	SIRIUS
Product designation	power contactor
General technical data:	
Size of contactor	SO
Degree of pollution	3
Mechanical service life (switching cycles)	
<ul> <li>of the contactor typical</li> </ul>	10 000 000
<ul> <li>of the contactor with added electronics- compatible auxiliary switch block typical</li> </ul>	5 000 000
<ul> <li>of the contactor with added auxiliary switch block typical</li> </ul>	10 000 000
Protection class IP	
• on the front	IP20
• of the terminal	IP20
Equipment marking	
• acc. to DIN EN 61346-2	Q
• acc. to DIN EN 81346-2	Q
Ambient conditions:	
Installation altitude at height above sea level maximum	2 000 m
Ambient temperature	
<ul> <li>during operation</li> </ul>	-25 +60 °C
Main circuit:	
Number of poles for main current circuit	3
Number of NC contacts for main contacts	0

Page 1/6

12.06.2015

Number of NO contacts for main contacts	3
Operating current	
• at AC-1 at 400 V	
— at ambient temperature 40 °C Rated value	40 A
• at AC-1 up to 690 V	
— at ambient temperature 40 °C Rated value	40 A
— at ambient temperature 60 °C Rated value	35 A
• at AC-3	
— at 400 V Rated value	25 A
• at AC-4 at 400 V Rated value	15.5 A
Operating current	
<ul> <li>with 1 current path at DC-1</li> </ul>	
— at 24 V Rated value	35 A
— at 110 V Rated value	4.5 A
<ul> <li>with 2 current paths in series at DC-1</li> </ul>	
— at 24 V Rated value	35 A
— at 110 V Rated value	35 A
<ul> <li>with 3 current paths in series at DC-1</li> </ul>	
— at 24 V Rated value	35 A
— at 110 V Rated value	35 A
Operating current	
<ul> <li>with 1 current path at DC-3 at DC-5</li> </ul>	
— at 24 V Rated value	20 A
— at 110 V Rated value	2.5 A
<ul> <li>with 2 current paths in series at DC-3 at DC-5</li> </ul>	
— at 110 V Rated value	15 A
— at 24 V Rated value	35 A
<ul> <li>with 3 current paths in series at DC-3 at DC-5</li> </ul>	
— at 110 V Rated value	35 A
— at 24 V Rated value	35 A
Active power loss at AC-3 at 400 V for rated value of	1.6 W
the operating current per conductor	
Control circuit/ Control:	
Type of voltage of the control supply voltage	AC
Control supply voltage with AC	
• at 50 Hz Rated value	220 V
• at 60 Hz Rated value	240 V
Rated value	50 Hz
Control supply voltage frequency 2 Rated value	60 Hz
Operating range factor control supply voltage rated value of the magnet coil with AC	
● at 50 Hz	0.8 1.1

• at 60 Hz	0.8 1.1
Apparent pick-up power of the magnet coil with AC	69 V·A
Inductive power factor with closing power of the coil	0.76
Apparent holding power of the magnet coil with AC	7.5 V·A
Inductive power factor with the holding power of the	0.28
coil	
Auxiliary circuit:	
Number of NC contacts	
<ul> <li>for auxiliary contacts</li> </ul>	
— instantaneous contact	2
Number of NO contacts	
<ul> <li>for auxiliary contacts</li> </ul>	
— instantaneous contact	2
Operating current at AC-12 maximum	10 A
Operating current at AC-15	
• at 230 V Rated value	6 A
• at 400 V Rated value	3 A
Operating current at DC-12	
• at 60 V Rated value	6 A
<ul> <li>at 110 V Rated value</li> </ul>	3 A
<ul> <li>at 220 V Rated value</li> </ul>	1 A
Operating current at DC-13	
• at 24 V Rated value	10 A
● at 60 V Rated value	2 A
● at 110 V Rated value	1 A
<ul> <li>at 220 V Rated value</li> </ul>	0.3 A
Contact reliability of the auxiliary contacts	1 faulty switching per 100 million (17 V, 1 mA)
Short-circuit:	
Design of the fuse link	
<ul> <li>for short-circuit protection of the main circuit</li> </ul>	
— with type of assignment 1 required	fuse gL/gG: 100 A
— with type of assignment 2 required	fuse gL/gG: 35 A
<ul> <li>for short-circuit protection of the auxiliary switch</li> </ul>	fuse gL/gG: 10 A
required	
Installation/ mounting/ dimensions:	
Mounting type	screw and snap-on mounting onto 35 mm standard mounting rail
	according to DIN EN 50022
Side-by-side mounting	Yes
Height	85 mm
Width	45 mm
Depth	140 mm

equired spacing	un a uta					
• for grounded	-	<u> </u>				
— at the side		0	6 mm			
onnections/ Term						
ype of electrical c	onnection					
<ul> <li>for main current circuit</li> </ul>		sc	screw-type terminals			
• for auxiliary and control current circuit			screw-type terminals			
ype of connectabl	e conductor cross-section	on				
<ul> <li>for main contain</li> </ul>	acts					
— solid		2×	2x (1 2.5 mm²), 2x (2.5 6 mm²), max. 2x 10 mm²			
— single or multi-stranded		2x	: (1 2,5 mm²), 2x (2,5	5 6 mm²), max. 2x	10 mm²	
— finely stra	anded with core end pro	cessing 2x	: (1 2.5 mm²), 2x (2.5	5 6 mm²)		
<ul> <li>for AWG cond</li> </ul>	ductors for main contact	s 2x	: (16 12), 2x (14 1	0), 1x 8		
ype of connectabl	e conductor cross-section	on				
<ul> <li>for auxiliary c</li> </ul>	ontacts					
— solid		2x	: (0.5 1.5 mm²), 2x (0	).75 2.5 mm²), ma	x. 2x (0.75 4 mr	
— finely stra	anded with core end pro	ocessing 2x	: (0.5 1.5 mm²), 2x (0	).75 2.5 mm²)		
<ul> <li>for AWG cond</li> </ul>	ductors for auxiliary con	tacts 2x	: (20 16), 2x (18 14	4), 1x 12		
ertificates/ appro	vals:	_				
General Produc			Functional	Declaration of	Test	
Contorar i rouau	or / approval		i anouonai	Doolaration	1000	
			Safety/Safety	Conformity	Certificates	
			Safety/Safety of Machinery	Conformity	Certificates	
6	<u> </u>			Conformity	Certificates	
(S))	(Junited Street)	C 0 r	of Machinery	Conformity	Type Test Certificates/Test	
() ()		EAC	of Machinery	CE	Type Test	
(SA)	UL	EHC	of Machinery	Conformity Cefection EG-Konf.	Type Test Certificates/Test	
CSA CSA	UL	EHC	of Machinery	CE	Type Test Certificates/Test	
CSA Test	UL Shipping Approva	LIIL	of Machinery	CE	Type Test Certificates/Test	
Certificates	UL	LIIL	of Machinery	CE	Type Test Certificates/Test	
Certificates Special Test	UL	LIIL	of Machinery Type Examination	CE	Type Test Certificates/Test	
Certificates	UL	LILLLLLLLLLLLLLLLLLLLLLLLLLLLLLLLLLLLL	of Machinery	CE	Type Test Certificates/Test	
Certificates Special Test	UL	LIIL	of Machinery Type Examination	CE	Type Test Certificates/Test	
Certificates Special Test	Shipping Approva		of Machinery Type Examination	EG-Konf.	Type Test Certificates/Test Report	
Certificates Special Test Certificate	UL Shipping Approva		of Machinery Type Examination	EG-Konf.	Type Test Certificates/Test Report	
Certificates Special Test Certificate Shipping	Shipping Approva		of Machinery Type Examination	EG-Konf.	Type Test Certificates/Test Report	
Certificates Special Test Certificate	UL         Shipping Approva         Image: Content of the		of Machinery Type Examination	EG-Konf.	Type Test Certificates/Test Report	
Certificates Special Test Certificate Shipping	UL Shipping Approva		of Machinery Type Examination	EG-Konf.	Type Test Certificates/Test Report	
Certificates Special Test Certificate Shipping	UL         Shipping Approva         Image: Constraint of the state of the stat		of Machinery Type Examination	EG-Konf.	Type Test Certificates/Test Report	

#### <sup>-</sup>urther information

Information- and Downloadcenter (Catalogs, Brochures,...) http://www.siemens.com/industrial-controls/catalogs

Industry Mall (Online ordering system) http://www.siemens.com/industrymall

#### Cax online generator

http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3RT10261AP64

Service&Support (Manuals, Certificates, Characteristics, FAQs,...) https://support.industry.siemens.com/cs/ww/en/ps/3RT10261AP64

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...) http://www.automation.siemens.com/bilddb/cax\_de.aspx?mlfb=3RT10261AP64&lang=en



